

# Self Inspection

## Communications

- Signage
- Accessible Routes



## Building Facilities

- Goods and Services
- Bathrooms and Locker Rooms
- Other Items (Water Fountains, Public Telephones, Etc.)



## Pedestrian Facilities

- Sidewalks
- Curb Ramps
- Pedestrian Signals
- Parking Spaces



# Sidewalk Inspections

## Common Issues:

- Incompliant slopes (cross-slope)
- Lip between sidewalk panels of over ¼-inch
- Sidewalk not wide enough for passing



# Curb Ramp Inspections

## Common Issues:

- Incompliant slopes (cross-slope or running slope)
- Lip between street and curb ramp of over ¼-inch
- No detectible warning



# Building Inspections

Evaluated City owned Buildings on Communication & Building Facilities by using *ADA Checklist for Existing Facilities* (Institute for Human Centered Design, 2016).

## Inspected Buildings:

- City Hall
- Police Department
- Senior Center
- Creekside
- Hunters Ridge Pool
- Gahanna Swimming Pool
- Gahanna Golf Course



# Communication Issues

- Incompliant sign height
- No signs designating accessible entrance
- Room signs do not have braille



# Building Facility Issues

- Inaccessible Doorways
- Non-compliant toilet (stall size, door locks)
- Non-compliant sink (pipes, mirror, dryer)



# Push Button Inspections

## Common Issues:

- Button does not have feedback (beep when pressed)
- Button too high from ground
- Button in inaccessible location

