

1501.17 INSPECTION, TESTING AND MAINTENANCE RECORDKEEPING. When required inspection, testing or maintenance occurs on any fire protection systems, applicable documentation shall be submitted to the fire code official, within 10 days, through an approved third-party inspection report system. Critical deficiencies, Red tagged and non-compliant issues shall be submitted to the fire code official within 48 hours. Reporting parties shall pay any fees associated with that service to the fire division's third-party provider.