

## STAFF COMMENTS

Project Name: Christian Meeting Room, Inc - Fred Kenimer Project Address: Ridenour Rd – Imperial Rise #3, Reserve A

The Fire Department does not have any concerns with the zoning change. We will address any developmental, or structural plans when they occur.

Respectfully Submitted By: Stephen Welsh Mifflin Township Fire Marshal





.....

## CITY OF GAHANNA

## STAFF COMMENTS

Project Name:

Olde Ridenour Road rezoning

Project Address:

Olde Ridenour Road

No comments.

Respectfully Submitted By:

Kenneth W. Fultz, P.E. Chief Building Official



Project Name:

Christian Meeting Room, Inc - Fred Kenimer

Project Address:

Ridenour Rd - Imperial Rise #3, Reserve "A"

## Service Dept/Engineering comments:

1. Sanitary sewer is available on the west side of Old Ridenour. It is an 8 inch line.

2. Water is available on the west side of Old Ridenour. It is an 8 inch line.

3. Storm detention and water quality design to be per Code Section 1193.

4. Erosion Control per Code Section 1195.

Respectfully Submitted By: Jeff Feltz Water Resources Engineer



Project Name:

Christian Meeting Room, Inc - Fred Kenimer

Project Address:

Ridenour Rd – Imperial Rise #3, Reserve "A"

Parks and recreation have no comment on the proposed change.

Respectfully Submitted By: Troy Euton, Deputy Director

